



June 2, 2010

POLYLOK INC./ZABEL
PETER GAVIN
3 FAIRFIELD BLVD
WALLINGFORD CT 06492

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
Manufacturer: POLYLOK INC./ZABEL
Product Name: EFFLUENT FILTER
Model Number(s): 3014-525 and 3014-625
Prevents solids >1/16 in. dia. and >1/32 in. dia., respectively from passing.
[MAX. DWF = 10,000 GPD; FITS 4- OR 6-IN. DIA. OUTLET]
Product File No: 20100245

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of OCTOBER 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- **MAINTENANCE: Clean filter at inspection/pumping interval.**

This approval supersedes the approval issued on 9/15/2009 under product file number 20050761. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050761.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Review
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV